

# Attestation of Conformity

No. N8A 075834 0841 Rev. 00

**Holder of Attestation:** **Shenzhen MEGMEET Electrical Co., Ltd.**

5th Floor, Tower A, B,C501-C503,D,E  
Unis Inforport, No.13 Langshan Road  
North Section, Hi-Tech Industrial Park  
Nanshan District  
518057 Shenzhen  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Programmable Controller**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 68240260691701

**Date,** 2026-08-12



( Alex Kong )

# Attestation of Conformity

No. N8A 075834 0841 Rev. 00

**Model(s):**

MU200-1210BTA, MU200-1210BRA, MU200-1616BTA,  
MU200-1616BRA, MU200-2424BTA, MU200-2424BRA,  
MU200-3232BTA, MU200-3232BRA, MU200-4040BTA,  
MU200-4040BRA, MU300-0808BTA, MU300-1210BTA,  
MU300-1210BRA, MU300-2424BTA, MU200-4DA,  
MU200-4AD, MU200-4PT, MU200-4AM, MU200-8TC,  
MU200-8AD, MU200-0808ERN, MU200-0808ETN,  
MU200-0016ERN, MU200-0016ETN, MU200-1600ENN

**Brand:**

**MEGMEET**

**MEGMEET**

**Parameters:**

Ratings: See below table for details

Remarks:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled.
- Open-type equipment, suitable enclosure should be provided in end system.
- The maximum operating temperature is 50°C.
- Clearance was evaluated for operating altitude up to 2000m above sea level.

**Tested  
according to:**

EN 61010-1:2010/A1:2019  
EN IEC 61010-2-201:2018

# Attestation of Conformity

No. N8A 075834 0841 Rev. 00

|                   | Model         | Input                     | Output      |
|-------------------|---------------|---------------------------|-------------|
| Main modules      | MU200-1210BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-1210BRA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-1616BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-1616BRA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-2424BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-2424BRA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-3232BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-3232BRA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-4040BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU200-4040BRA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU300-0808BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU300-1210BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU300-1210BRA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
|                   | MU300-2424BTA | 100-240VAC, 50/60Hz, 1.0A | 24VDC, 0.3A |
| Expansion modules | MU200-4DA     | 24VDC, 0.3A               | --          |
|                   | MU200-4AD     | 24VDC, 0.1A               | --          |
|                   | MU200-4PT     | 24VDC, 0.1A               | --          |
|                   | MU200-4AM     | 24VDC, 0.1A               | --          |
|                   | MU200-8TC     | 24VDC, 0.1A               | --          |
|                   | MU200-8AD     | 24VDC, 0.1A               | --          |
|                   | MU200-0808ERN | 24VDC, 0.1A               | --          |
|                   | MU200-0808ETN | 24VDC, 0.1A               | --          |
|                   | MU200-0016ERN | 24VDC, 0.1A               | --          |
|                   | MU200-0016ETN | 24VDC, 0.1A               | --          |
|                   | MU200-1600ENN | 24VDC, 0.1A               | --          |